

Clause 58: Apartment Developments

Address : 14 Alma Road

URBAN CONTEXT

TITLE & OBJECTIVE	Assessment
<p>CLAUSE 58.01-1 Application requirements</p> <p>An application must be accompanied by:</p> <ul style="list-style-type: none"> • An urban context report. • A design response. 	<p>All relevant and appropriate information has been submitted.</p>
<p>CLAUSE 58.01-2 Urban context report</p> <p>The urban context report may use a site plan, photographs or other techniques.</p>	<p>As above.</p>
<p>CLAUSE 58.01-3 Design response</p> <ul style="list-style-type: none"> • The design response must explain how the proposed design: <ul style="list-style-type: none"> – Responds to any relevant planning provision that applies to the land. – Meets the objectives of Clause 58. – Responds to any relevant housing, urban design and landscape plan, strategy or policy set out in this scheme. – Derives from and responds to the urban context report. • The design response must include correctly proportioned street elevations or photographs showing the development in the context of adjacent buildings. • If in the opinion of the responsible authority this requirement is not relevant to the evaluation of an application, it may waive or reduce the requirement. 	<p>As above with the applicant's explanation of the proposal being lodged within its planning report.</p>
<p>CLAUSE 58.02-1 Urban context objectives</p> <ul style="list-style-type: none"> • To ensure that the design responds to the existing urban context or contributes to the preferred future development of the area. • To ensure that development responds to the features of the site and the surrounding area. <p>Standard D1</p> <ul style="list-style-type: none"> • The design response must be appropriate to the urban context and the site. • The proposed design must respect the existing or preferred urban context and 	<p>This matter has been addressed in the body of this report and subject to deletion of two levels from the taller south element and one from the lower north element, it is considered that the proposal would suitably fit its context.</p>

<p>respond to the features of the site.</p>	
<p>CLAUSE 58.02-2 Residential policy objectives</p> <ul style="list-style-type: none"> • To ensure that residential development is provided in accordance with any policy for housing in the Municipal Planning Strategy and the Planning Policy Framework. • To support higher density residential development where development can take advantage of public and community infrastructure and services. <p>Standard D2</p> <ul style="list-style-type: none"> • An application must be accompanied by a written statement to the satisfaction of the responsible authority that describes how the development is consistent with any relevant policy for housing in the Municipal Planning Strategy and the Planning Policy Framework. 	<p>As above with all the relevant material being submitted.</p>
<p>CLAUSE 58.02-3 Dwelling diversity objective</p> <ul style="list-style-type: none"> • To encourage a range of dwelling sizes and types in developments of ten or more dwellings. <p>Standard D3</p> <ul style="list-style-type: none"> • Developments of ten or more dwellings should provide a range of dwelling sizes and types, including dwellings with a different number of bedrooms. 	<p>The development provides a mix of one and two bedroom apartments, with varying orientations and sizes. The absence of three bedroom dwellings is noted but is not considered to detrimentally diminish the proposed extent of dwelling variation.</p>
<p>CLAUSE 58.02-4 Infrastructure objectives</p> <ul style="list-style-type: none"> • To ensure development is provided with appropriate utility services and infrastructure. • To ensure development does not unreasonably overload the capacity of utility services and infrastructure. <p>Standard D4</p> <ul style="list-style-type: none"> • Development should be connected to reticulated services, including reticulated sewerage, drainage, electricity and gas, if available. • Development should not unreasonably exceed the capacity of utility services and infrastructure, including reticulated services and roads. • In areas where utility services or infrastructure have little or no spare capacity, developments should provide for 	<p>All necessary infrastructure is available.</p>

<p>the upgrading of or mitigation of the impact on services or infrastructure.</p>	
<p>CLAUSE 58.02-5 Integration with the street objective</p> <ul style="list-style-type: none"> • To integrate the layout of development with the street. • To support development that activates street frontage. <p>Standard D5</p> <ul style="list-style-type: none"> • Developments should be oriented to front existing and proposed streets. • Along street frontage, development should: <ul style="list-style-type: none"> – Incorporate pedestrian entries, windows, balconies or other active spaces. – Limit blank walls. – Limit high front fencing, unless consistent with the existing urban context. – Provide low and visually permeable front fences, where proposed. – Conceal car parking and internal waste collection areas from the street. • Development next to existing public open space should be designed to complement the open space and facilitate passive surveillance. 	<p>The development would provide for separate vehicle and (multiple) pedestrian access points from the laneway and St Kilda Road respectively.</p> <p>It is considered that acceptable activation and passive surveillance are achieved due to the retail uses at ground floor fronting both Alma and St. Kilda Roads.</p> <p>Further, blank walls would be largely absent with balconies and window openings above ground level to achieve passive surveillance.</p> <p>The existing crossover to Alma Road would be utilised. It is considered that car parking and internal waste collection would both be well concealed from the streetscape.</p>

CLAUSE 58.03 - SITE LAYOUT

TITLE & OBJECTIVE	Assessment
<p>CLAUSE 58.03-1 Energy efficiency objectives</p> <ul style="list-style-type: none"> • To achieve and protect energy efficient dwellings and buildings. • To ensure the orientation and layout of development reduce fossil fuel energy use and make appropriate use of daylight and solar energy. • To ensure dwellings achieve adequate thermal efficiency <p>Standard D6</p> <p>Buildings should be:</p> <ul style="list-style-type: none"> • Oriented to make appropriate use of solar energy. • Sited and designed to ensure that the energy efficiency of existing dwellings on adjoining lots is not unreasonably reduced. • Living areas and private open space should be located on the north side of the 	<p>ESD documents have been received. Some deficiencies have been identified and some measures should be better achieved, as per the recommended conditions. But it is not considered that appropriate ESD standards could not be achieved that would be fatal to the application.</p>

<p>development, if practicable.</p> <ul style="list-style-type: none"> • Developments should be designed so that solar access to north-facing windows is optimised. <p>Dwellings located in a climate zone identified in Table D1 should not exceed the maximum NatHERS annual cooling load specified in the following table.</p>	
<p>CLAUSE 58.03-2</p> <p>Communal open space objective</p> <ul style="list-style-type: none"> • To provide communal open space that meets the recreation and amenity needs of residents. • To ensure that communal open space is accessible, practical, attractive, easily maintained. • To ensure that communal open space is integrated with the layout of the development and enhances resident amenity. <p>Standard D7</p> <ul style="list-style-type: none"> • A development of 10 or more dwellings should provide a minimum area of communal outdoor open space of 30 square metres. • If a development contains 13 or more dwellings, the development should also provide an additional minimum area of communal open space of 2.5 square metres per dwelling or 220 square metres, whichever is the lesser. This additional area may be indoors or outdoors and may consist of multiple separate areas of communal open space. • Each area of communal open space should be: <ul style="list-style-type: none"> – Accessible to all residents. – A useable size, shape and dimension. – Capable of efficient management. – Located to: <ul style="list-style-type: none"> – Provide passive surveillance opportunities, where appropriate. – Provide outlook for as many dwellings as practicable. – Avoid overlooking into habitable rooms and private open space of new dwellings. – Minimise noise impacts to new and existing dwellings. • Any area of communal outdoor open space should be landscaped and include canopy cover and trees. 	<p>The proposal includes 220m² of outdoor communal open space and 150m² of internal communal open space located at fourteenth floor, representing 370m² of open space, complying with the standard.</p> <p>Additionally, the location, access and functionality of the spaces is considered acceptable and it is considered that the spaces would be well utilised.</p> <p>It is considered sufficient landscaping opportunities are provided. A landscape plan will be required by way of permit condition.</p>

<p>CLAUSE 58.03-3</p> <p>Solar access to communal outdoor open space objective</p> <ul style="list-style-type: none"> To allow solar access into communal outdoor open space. <p>Standard D8</p> <ul style="list-style-type: none"> The communal outdoor open space should be located on the north side of a building, if appropriate. <p>At least 50 per cent or 125 square metres, whichever is the lesser, of the primary communal outdoor open space should receive a minimum of two hours of sunlight between 9am and 3pm on 21 June.</p>	<p>The communal open space would have excellent access to sunlight due to its strong north orientation.</p> <p>Further, there is no existing or proposed taller built form to the north of the open space (noting its fourteenth floor location).</p>
<p>CLAUSE 58.03-4</p> <p>Safety objective</p> <ul style="list-style-type: none"> To ensure the layout of development provides for the safety and security of residents and property. <p>Standard D9</p> <ul style="list-style-type: none"> Entrances to dwellings should not be obscured or isolated from the street and internal accessways. Planting which creates unsafe spaces along streets and accessways should be avoided. Developments should be designed to provide good lighting, visibility and surveillance of car parks and internal accessways. <p>Private spaces within developments should be protected from inappropriate use as public thoroughfares.</p>	<p>The pedestrian entries would be safe and well defined.</p>
<p>CLAUSE 58.03-5</p> <p>Landscaping objectives</p> <ul style="list-style-type: none"> To provide landscaping that supports the existing or preferred urban context of the area and reduces the visual impact of buildings on the streetscape. To preserve existing canopy cover and support the provision of new canopy cover. To ensure landscaping is climate responsive, supports biodiversity, wellbeing and amenity and reduces urban heat. <p>Standard D10</p> <ul style="list-style-type: none"> Development should retain existing trees and canopy cover Development should provide for the 	<p>There is no existing strong landscape character within the surrounding Alma or St Kilda Road areas.</p> <p>It is considered that the development would achieve an appropriate balance between responding to the DDO36 built form outcomes and would have some (albeit limited) opportunities for new landscaping where possible, including the prescribed 2m setback to Alma Road. A landscape plan is recommended to reinforce this.</p>

<p>replacement of any significant trees that have been removed in the 12 months prior to the application being made.</p> <ul style="list-style-type: none"> • Development should: <ul style="list-style-type: none"> – Provide the canopy cover and deep soil areas specified in Table D2. Existing trees can be used to meet the canopy cover requirements of Table D2. – Provide canopy cover through canopy trees that are: <ul style="list-style-type: none"> – Located in an area of deep soil specified in Table D3. Where deep soil cannot be provided trees should be provided in planters specified in Table D3. – Consistent with the canopy diameter and height at maturity specified in Table D4. – Located in communal outdoor open space or common areas or street frontages. • Comprise smaller trees, shrubs and ground cover, including flowering native species. Include landscaping, such as climbing plants or smaller plants in planters, in the street frontage and in outdoor areas, including communal outdoor open space. • Shade outdoor areas exposed to summer sun through landscaping or shade structures and use paving and surface materials that lower surface temperatures and reduce heat absorption. • Be supported by irrigation systems which utilise alternative water sources such as rainwater, stormwater and recycled water. • Protect any predominant landscape features of the area. • Take into account the soil type and drainage patterns of the site. • Provide a safe, attractive and functional environment for residents. • Specify landscape themes, vegetation (location and species), irrigation systems, paving and lighting. 	
---	--

Table D2 Canopy cover and deep soil requirements		
Site area	Canopy cover	Deep soil
1000 square metres	5% of site area Include at least 1 Type A tree	5% of site area or 12 square metres whichever is the greater
1001 - 1500 square metres	50 square metres plus 20% of site area above 1,000 square metres Include at least 1 Type B tree	7.5% of site area
1501 - 2500 square metres	150 square metres plus 20% of site area above 1,500 square metres Include at least 2 Type B trees or 1 Type C tree	10% of site area
2500 square metres or more	350 square metres plus 20% of site area above 2,500 square metres Include at least 2 Type B trees or 1 Type C tree	15% of site area

Table D3 Soil requirements for trees			
Tree type	Tree in deep soil	Tree in planter	Depth of planter soil
	Area of deep soil	Volume of planter soil	
A	12 square metres (min. plan dimension 2.5 metres)	12 cubic metres (min. plan dimension of 2.5 metres)	0.8 metre
B	49 square metres (min. plan dimension 4.5 metres)	28 cubic metres (min. plan dimension of 4.5 metres)	1 metre
C	121 square metres (min. plan dimension 6.5 metres)	64 cubic metres (min. plan dimension of 6.5 metres)	1.5 metre

Note: Where multiple trees share the same section of soil the total required amount of soil can be reduced by 5% for every additional tree, up to a maximum reduction of 25%.

Table D4 Tree type		
Tree type	Minimum canopy diameter at maturity	Minimum height at maturity
A	4 metres	6 metres
B	8 metres	8 metres
C	12 metres	12 metres

<p>CLAUSE 58.03-6</p> <p>Access objective</p> <ul style="list-style-type: none"> To ensure that vehicle crossovers are designed and located to provide safe access for pedestrians, cyclists and other vehicles. To ensure the vehicle crossovers are designed and located to minimise visual impact. <p>Standard D11</p> <ul style="list-style-type: none"> Vehicle crossovers should be minimised Car parking entries should be consolidated, minimised in size, integrated with the façade and where practicable located at the side or rear of the building The location of crossovers should maximise pedestrian safety and the retention of on-street car parking spaces and street trees. <p>Developments must provide for access for service, emergency and delivery vehicles.</p>	<p>There would only be one vehicle access point from Alma Road (utilising an existing crossover and side lane).</p> <p>No vehicle access would be provided from St Kilda Road (within a Transport Zone).</p> <p>The existing easternmost crossover on Alma Road would be removed, with kerbing and footpath being reinstated to Council's standards.</p> <p>Appropriate access for services, emergency and delivery vehicles would be achieved.</p>
<p>CLAUSE 58.03-7</p> <p>Parking location objectives</p> <ul style="list-style-type: none"> To provide convenient parking for resident and visitor vehicles. To protect residents from vehicular noise within developments. 	<p>Three levels of basement car parking are proposed, along with four at grade spaces accessed from the lane, with car parking provided mostly in a stacker arrangement. All parking spaces would be convenient, safe and secure and would have adequate turning room and queuing room behind the car lifts.</p>

<p>Standard D12</p> <p>Car parking facilities should:</p> <ul style="list-style-type: none"> • Be reasonably close and convenient to dwellings. • Be secure. Be well ventilated if enclosed. 	
<p>CLAUSE 58.03-8</p> <p>Integrated water and stormwater management objectives</p> <ul style="list-style-type: none"> • To encourage the use of alternative water sources such as rainwater, stormwater and recycled water. • To facilitate stormwater collection, utilisation and infiltration within the development. • To encourage development that reduces the impact of stormwater run-off on the drainage system and filters sediment and waste from stormwater prior to discharge from the site. <p>Standard D13</p> <ul style="list-style-type: none"> • Buildings should be designed to collect rainwater for non-drinking purposes such as flushing toilets, laundry appliances and garden use. • Buildings should be connected to a non-potable dual pipe reticulated water supply, where available from the water authority. <p>The stormwater management system should be:</p> <ul style="list-style-type: none"> • Designed to meet the current best practice performance objectives for stormwater quality as contained in the <i>Urban Stormwater - Best Practice Environmental Management Guidelines</i> (Victorian Stormwater Committee, 1999). <p>Designed to maximise infiltration of stormwater, water and drainage of residual flows into permeable surfaces, tree pits and treatment areas.</p>	<p>All stormwater and ESD matters have been addressed should a permit be issued, subject to additional updates being required to the plans and SMP via recommended conditions.</p>

CLAUSE 58.04 - AMENITY IMPACTS

TITLE & OBJECTIVE	Assessment
<p>CLAUSE 58.04-1</p> <p>Building setback objectives</p> <ul style="list-style-type: none"> • To ensure the setback of a building from a boundary appropriately responds to the existing urban context or contributes to the preferred future development of the area. • To allow adequate daylight into new dwellings. 	<p>The provisions of the DDO36 apply to this local precinct which has been addressed / assessed in this report with all setbacks being compliant.</p>

<ul style="list-style-type: none"> To limit views into habitable room windows and private open space of new and existing dwellings. To provide a reasonable outlook from new dwellings. To ensure the building setbacks provide appropriate internal amenity to meet the needs of residents. <p>Standard D14</p> <ul style="list-style-type: none"> The built form of the development must respect the existing or preferred urban context and respond to the features of the site. Buildings should be set back from side and rear boundaries, and other buildings within the site to: <ul style="list-style-type: none"> Ensure adequate daylight into new habitable room windows. Avoid direct views into habitable room windows and private open space of new and existing dwellings. Developments should avoid relying on screening to reduce views. Provide an outlook from dwellings that creates a reasonable visual connection to the external environment. <p>Ensure the dwellings are designed to meet the objectives of Clause 58.</p>	
<p>CLAUSE 58.04-2</p> <p>Internal views objective</p> <p>To limit views into the private open space and habitable room windows of dwellings within a development.</p> <p>Standard D15</p> <p>Windows and balconies should be designed to prevent overlooking of more than 50 per cent of the private open space of a lower-level dwelling directly below and within the same development.</p>	<p>There would be no unreasonable internal views and no additional screening to protect internal views is needed.</p>
<p>CLAUSE 58.04-3</p> <p>Noise impacts objectives</p> <ul style="list-style-type: none"> To contain noise sources in developments that may affect existing dwellings. To protect residents from external and internal noise sources. <p>Standard D16</p> <ul style="list-style-type: none"> Noise sources, such as mechanical plants should not be located near bedrooms of immediately adjacent existing dwellings. The layout of new dwellings and buildings should minimise noise transmission within the site. Noise sensitive rooms (such as living areas and bedrooms) should be located to avoid 	<p>Plant and equipment would be sited away from habitable rooms (located on the roof).</p> <p>The lift core would not abut any noise sensitive rooms.</p> <p>The plans confirm the following:</p> <ul style="list-style-type: none"> Bedrooms would achieve no greater than 35dB(A) between 10pm and 6am; and Living areas would achieve no greater than 40dB(a) between 6am and 10pm.

<p>noise impacts from mechanical plants, lifts, building services, non-residential uses, car parking, communal areas and other dwellings.</p> <ul style="list-style-type: none"> • New dwellings should be designed and constructed to include acoustic attenuation measures to reduce noise levels from off-site noise sources. • Buildings within a noise influence area specified in Table D5 should be designed and constructed to achieve the following noise levels: <ul style="list-style-type: none"> – Not greater than 35dB(A) for bedrooms, assessed as an LAeq,8h from 10pm to 6am. – Not greater than 40dB(A) for living areas, assessed as an LAeq,16h from 6am to 10pm <p>Table D5 Noise influence area</p> <table border="1"> <thead> <tr> <th>Noise source</th> <th>Noise influence area</th> </tr> </thead> <tbody> <tr> <td colspan="2">Zone interface</td> </tr> <tr> <td>Industry</td> <td>300 metres from the Industrial 1, 2 and 3 zone boundary</td> </tr> <tr> <td colspan="2">Roads</td> </tr> <tr> <td>Freeways, tollways and other roads carrying 40,000 Annual Average Daily Traffic Volume</td> <td>300 metres from the nearest trafficable lane</td> </tr> <tr> <td colspan="2">Railways</td> </tr> <tr> <td>Railway servicing passengers in Victoria</td> <td>80 metres from the centre of the nearest track</td> </tr> <tr> <td>Railway servicing freight outside Metropolitan Melbourne</td> <td>80 metres from the centre of the nearest track</td> </tr> <tr> <td>Railway servicing freight in Metropolitan Melbourne</td> <td>135 metres from the centre of the nearest track</td> </tr> </tbody> </table> <p><i>Note: The noise influence area should be measured from the closest part of the building to the noise source.</i></p> <ul style="list-style-type: none"> • Buildings, or part of a building screened from a noise source by an existing solid structure, or the natural topography of the land, do not need to meet the specified noise level requirements. • Noise levels should be assessed in unfurnished rooms with a finished floor and the windows closed. 	Noise source	Noise influence area	Zone interface		Industry	300 metres from the Industrial 1, 2 and 3 zone boundary	Roads		Freeways, tollways and other roads carrying 40,000 Annual Average Daily Traffic Volume	300 metres from the nearest trafficable lane	Railways		Railway servicing passengers in Victoria	80 metres from the centre of the nearest track	Railway servicing freight outside Metropolitan Melbourne	80 metres from the centre of the nearest track	Railway servicing freight in Metropolitan Melbourne	135 metres from the centre of the nearest track	
Noise source	Noise influence area																		
Zone interface																			
Industry	300 metres from the Industrial 1, 2 and 3 zone boundary																		
Roads																			
Freeways, tollways and other roads carrying 40,000 Annual Average Daily Traffic Volume	300 metres from the nearest trafficable lane																		
Railways																			
Railway servicing passengers in Victoria	80 metres from the centre of the nearest track																		
Railway servicing freight outside Metropolitan Melbourne	80 metres from the centre of the nearest track																		
Railway servicing freight in Metropolitan Melbourne	135 metres from the centre of the nearest track																		
<p>Clause 58.04-4</p> <p>Wind impacts objective</p> <ul style="list-style-type: none"> • To ensure the built form, design and layout of development does not generate unacceptable wind impacts within the site or on surrounding land. <p>Standard D17</p> <ul style="list-style-type: none"> • Development of five or more storeys, excluding a basement should: <ul style="list-style-type: none"> – not cause unsafe wind conditions specified in Table D6 in public land, publicly accessible areas on private land, private open space and communal open space; – and achieve comfortable wind conditions specified in Table D6 in public land and 	<p>The Desktop Pedestrian Level Wind Study prepared by GWTS (lodged with the application material) confirms the predicted wind conditions to be reasonable and appropriate and would meet with the relevant tests.</p>																		

<p>publicly accessible areas on private land within a distance of half the greatest length of the building, or half the total height of the building measured outwards on the horizontal plane from the ground floor building façade, whichever is greater.</p> <ul style="list-style-type: none"> • Trees and landscaping should not be used to mitigate wind impacts. This does not apply to sitting areas, where trees and landscaping may be used to supplement fixed wind mitigation elements. • Wind mitigation elements, such as awnings and screens should be located within the site boundary, unless consistent with the existing urban context or preferred future development of the area. 	
--	--

CLAUSE 58.05 - ON-SITE AMENITY AND FACILITIES

TITLE & OBJECTIVE	Assessment
<p>CLAUSE 58.05-1 Accessibility objective</p> <ul style="list-style-type: none"> • To ensure the design of dwellings meets the needs of people with limited mobility. <p>Standard D18</p> <ul style="list-style-type: none"> • At least 50 per cent of dwellings should have: <ul style="list-style-type: none"> – A clear opening width of at least 850mm at the entrance to the dwelling and main bedroom. – A clear path with a minimum width of 1.2 metres that connects the dwelling entrance to the main bedroom, an adaptable bathroom and the living area. – A main bedroom with access to an adaptable bathroom. • At least 50 per cent of dwellings should have: <ul style="list-style-type: none"> – At least one adaptable bathroom that meets all of the requirements of either Design A or Design B specified in Table D7. 	<p>Over 50% of apartments (and of various types) meet the requirements of the Standard. This is confirmed on Plan TP011 –which provides further details.</p>

Table D7 Bathroom design		
	Design option A	Design option B
Door opening	A clear 850mm wide door opening.	A clear 620mm wide door opening located opposite the shower.
Door design	Either: <ul style="list-style-type: none"> A slide door, or A door that opens outwards, or A door that opens inwards that is clear of the circulation area and has readily removable hinges. 	Either: <ul style="list-style-type: none"> A slide door, or A door that opens outwards, or A door that opens inwards and has readily removable hinges.
Circulation area	A clear circulation area that is: <ul style="list-style-type: none"> A minimum area of 1.2 metres by 1.2 metres. Located in front of the shower and the toilet. Clear of the toilet, basin and the door swing. The circulation area for the toilet and shower can overlap.	A clear circulation area that is: <ul style="list-style-type: none"> A minimum width of 1 metre. The full length of the bathroom and a minimum length of 2.7 metres. Clear of the toilet and basin. The circulation area can include a shower area.
Path to circulation area	A clear path with a minimum width of 900mm from the door opening to the circulation area.	Not applicable.
Shower	A hobless (step-free) shower.	A hobless (step-free) shower that has a removable shower screen and is located on the furthest wall from the door opening.
Toilet	A toilet located in the corner of the room.	A toilet located closest to the door opening and clear of the circulation area.

<p>CLAUSE 58.05-2</p> <p>58.05-2 Building entry and circulation objectives</p> <ul style="list-style-type: none"> To provide each dwelling and building with its own sense of identity. To ensure the internal layout of buildings provide for the safe, functional and efficient movement of residents. To ensure internal communal areas provide adequate access to daylight and natural ventilation. <p>Standard D19</p> <p>Entries to dwellings and buildings should:</p> <ul style="list-style-type: none"> Be visible and easily identifiable. Provide shelter, a sense of personal address and a transitional space around the entry. <p>The layout and design of buildings should:</p> <ul style="list-style-type: none"> Clearly distinguish entrances to residential and non-residential areas. Provide windows to building entrances and lift areas. Provide visible, safe and attractive stairs from the entry level to encourage use by residents. Provide common areas and corridors that: <ul style="list-style-type: none"> Include at least one source of natural light and natural ventilation. Avoid obstruction from building services. <p>Maintain clear sight lines.</p>	<p>The residential entry to the building is considered to be clearly identifiable along St Kilda Road.</p> <p>Stairs would be located adjacent to the lift.</p> <p>Corridors would be unobstructed, and considered to achieve adequate sight lines being open to their western end, enabling daylighting and ventilation.</p>
<p>CLAUSE 58.05-3</p> <p>Private open space objective</p> <p>To provide adequate private open space for the reasonable recreation and service needs of residents.</p> <p>Standard D20</p> <p>A dwelling should have private open space consisting of at least one of the following:</p> <ul style="list-style-type: none"> An area of 25 square metres, with a minimum 	<p>The apartments would have open space in the form of balconies of no less than 9.5m² in area. Some balconies would be larger than 9.5m².</p> <p>Where air conditioning and heating units are proposed on balconies, an additional 1.5m² in area would be provided.</p>

<p>dimension of 3 metres and convenient access from a living room.</p> <ul style="list-style-type: none"> • A balcony with at least the area and dimensions specified in Table D8 and convenient access from a living room. • An area on a podium or other similar base of at least 15 square metres, with a minimum dimension of 3 metres and convenient access from a living room, or • An area on a roof of 10 square metres with a minimum dimension of 2 metres and convenient access from a living room. <p>If a cooling or heating unit is located on a balcony, the minimum balcony area specified in Table D8 should be increased by at least 1.5 square metres.</p> <p>If the finished floor level of a dwelling is 40 metres or more above ground level, the requirements of Table D8 do not apply if at least the area specified in Table D9 is provided as living area or bedroom area in addition to the minimum area specified in Table D11 or Table D12 in Standard D25.</p> <p>Table D8 Balcony size</p> <table border="1"> <thead> <tr> <th>Dwelling type</th> <th>Minimum area</th> <th>Minimum dimension</th> </tr> </thead> <tbody> <tr> <td>Studio or 1 bedroom dwelling</td> <td>8 square metres</td> <td>1.8 metres</td> </tr> <tr> <td>2 bedroom dwelling</td> <td>8 square metres</td> <td>2 metres</td> </tr> </tbody> </table> <table border="1"> <thead> <tr> <th>Dwelling type</th> <th>Minimum area</th> <th>Minimum dimension</th> </tr> </thead> <tbody> <tr> <td>3 or more bedroom dwelling</td> <td>12 square metres</td> <td>2.4 metres</td> </tr> </tbody> </table> <p>Table D9 Additional living area or bedroom area</p> <table border="1"> <thead> <tr> <th>Dwelling type</th> <th>Additional area</th> </tr> </thead> <tbody> <tr> <td>Studio or 1 bedroom dwelling</td> <td>8 square metres</td> </tr> <tr> <td>2 bedroom dwelling</td> <td>8 square metres</td> </tr> <tr> <td>3 or more bedroom dwelling</td> <td>12 square metres</td> </tr> </tbody> </table>	Dwelling type	Minimum area	Minimum dimension	Studio or 1 bedroom dwelling	8 square metres	1.8 metres	2 bedroom dwelling	8 square metres	2 metres	Dwelling type	Minimum area	Minimum dimension	3 or more bedroom dwelling	12 square metres	2.4 metres	Dwelling type	Additional area	Studio or 1 bedroom dwelling	8 square metres	2 bedroom dwelling	8 square metres	3 or more bedroom dwelling	12 square metres	<p>The balconies would generally comply with the minimum areas and minimum dimensions set out in Tables D8 and D9.</p> <p>Further, there is generous communal open space proposed for all residents at level 14 which would exceed the requirements of this clause.</p>
Dwelling type	Minimum area	Minimum dimension																						
Studio or 1 bedroom dwelling	8 square metres	1.8 metres																						
2 bedroom dwelling	8 square metres	2 metres																						
Dwelling type	Minimum area	Minimum dimension																						
3 or more bedroom dwelling	12 square metres	2.4 metres																						
Dwelling type	Additional area																							
Studio or 1 bedroom dwelling	8 square metres																							
2 bedroom dwelling	8 square metres																							
3 or more bedroom dwelling	12 square metres																							
<p>CLAUSE 58.05-4</p> <p>Storage objective</p> <p>To provide adequate storage facilities for each dwelling.</p> <p>Standard D21</p> <ul style="list-style-type: none"> • Each dwelling should have convenient access to useable and secure storage space. • The total minimum storage space (including kitchen, bathroom and bedroom storage) should meet the requirements specified in Table D10. <p>Table D10 Storage</p> <table border="1"> <thead> <tr> <th>Dwelling type</th> <th>Total minimum storage volume</th> <th>Minimum storage volume within the dwelling</th> </tr> </thead> <tbody> <tr> <td>Studio</td> <td>8 cubic metres</td> <td>5 cubic metres</td> </tr> <tr> <td>1 bedroom dwelling</td> <td>10 cubic metres</td> <td>6 cubic metres</td> </tr> <tr> <td>2 bedroom dwelling</td> <td>14 cubic metres</td> <td>9 cubic metres</td> </tr> <tr> <td>3 or more bedroom dwelling</td> <td>18 cubic metres</td> <td>12 cubic metres</td> </tr> </tbody> </table>	Dwelling type	Total minimum storage volume	Minimum storage volume within the dwelling	Studio	8 cubic metres	5 cubic metres	1 bedroom dwelling	10 cubic metres	6 cubic metres	2 bedroom dwelling	14 cubic metres	9 cubic metres	3 or more bedroom dwelling	18 cubic metres	12 cubic metres	<p>All one bedroom apartments would have a minimum total storage volume of 10m³ comprising a minimum of 3m³ of external storage and a minimum of 7m³ of internal storage.</p> <p>All two bedroom apartments would have a minimum total storage volume of 13m³, comprising a minimum of 3m³ of external storage and a minimum of 11m³ of internal storage. This would not comply with the standard (14m³). The degree of non-compliance is minimal and is considered acceptable.</p>								
Dwelling type	Total minimum storage volume	Minimum storage volume within the dwelling																						
Studio	8 cubic metres	5 cubic metres																						
1 bedroom dwelling	10 cubic metres	6 cubic metres																						
2 bedroom dwelling	14 cubic metres	9 cubic metres																						
3 or more bedroom dwelling	18 cubic metres	12 cubic metres																						

CLAUSE 58.06 - DETAILED DESIGN

TITLE & OBJECTIVE	Assessment
-------------------	------------

<p>CLAUSE 58.06-1</p> <p>Common property objectives</p> <ul style="list-style-type: none"> • To ensure that communal open space, car parking, access areas and site facilities are practical, attractive and easily maintained. • To avoid future management difficulties in areas of common ownership. <p>Standard D22</p> <ul style="list-style-type: none"> • Developments should clearly delineate public, communal and private areas. • Common property, where provided, should be functional and capable of efficient management. 	<p>The public, communal and private areas within the development are clearly delineated. All common property is considered functional and capable of management by the Owners Corporation and as previously noted, is considered likely to be well used.</p>
<p>CLAUSE 58.06-2</p> <p>Site services objectives</p> <ul style="list-style-type: none"> • To ensure that site services are accessible and can be installed and maintained. • To ensure that site services and facilities are visually integrated into the building design or landscape. <p>Standard D23</p> <ul style="list-style-type: none"> • Development should provide adequate space (including easements where required) for site services to be installed and maintained efficiently and economically. • Meters and utility services should be designed as an integrated component of the building or landscape. • Mailboxes and other site facilities should be adequate in size, durable, water-protected, located for convenient access and integrated into the overall design of the development. 	<p>Services and installations would be at ground level. Their design would be consistent with that of the remainder of the building.</p> <p>Mailboxes are shown within the residential lobby and entrance off St Kilda Road.</p>
<p>CLAUSE 58.06-3</p> <p>Waste and recycling objectives</p> <ul style="list-style-type: none"> • To ensure dwellings are designed to encourage waste recycling. • To ensure that waste and recycling facilities are accessible, adequate and attractive. • To ensure that waste and recycling facilities are designed and managed to minimise impacts on residential amenity, health and the public realm. <p>Standard D24</p> <p>Developments should include dedicated areas for:</p> <ul style="list-style-type: none"> • Waste and recycling enclosures which are: <ul style="list-style-type: none"> – Adequate in size, durable, waterproof 	<p>A waste room is depicted at ground level with separate residential and commercial bin areas. The waste room is considered to be acceptable in size and dimensions.</p> <p>A Waste Management Plan forms part of the application material which confirms that adequate waste storage and facilities are provided and confirms best practice is achieved.</p> <p>Council's Waste Department raised no concerns but suggested inclusion of a charity bin. (Refer condition1 (m))</p>

<p>and blend in with the development.</p> <ul style="list-style-type: none"> - Adequately ventilated. - Located and designed for convenient access by residents and made easily accessible to people with limited mobility. <ul style="list-style-type: none"> • Adequate facilities for bin washing. These areas should be adequately ventilated. • Collection, separation and storage of waste and recyclables, including where appropriate opportunities for on-site management of food waste through composting or other waste recovery as appropriate. • Collection, storage and reuse of garden waste, including opportunities for on-site treatment, where appropriate, or off-site removal for reprocessing. • Adequate circulation to allow waste and recycling collection vehicles to enter and leave the site without reversing. • Adequate internal storage space within each dwelling to enable the separation of waste, recyclables and food waste where appropriate. <p>Waste and recycling management facilities should be designed and managed in accordance with a Waste Management Plan approved by the responsible authority and:</p> <ul style="list-style-type: none"> • Be designed to meet the better practice design options specified in <i>Waste Management and Recycling in Multi-unit Developments (Sustainability Victoria, 2019)</i>. • Protect public health and amenity of residents and adjoining premises from the impacts of odour, noise and hazards associated with waste collection vehicle movements. 	
<p>CLAUSE 58.06-4</p> <p>External walls and materials objective</p> <ul style="list-style-type: none"> • To ensure external walls use materials appropriate to the existing urban context or preferred future development of the area. • To ensure external walls endure and retain their attractiveness. <p>Standard D25</p> <ul style="list-style-type: none"> • External walls should be finished with materials that: <ul style="list-style-type: none"> - Do not easily deteriorate or stain. - Weather well over time. - Are resilient to the wear and tear from their intended use. • External wall design should facilitate safe and convenient access for maintenance. 	<p>The external materials and finishes are considered to be of a high contemporary standard and would offer acceptable durability and resilience over time. No urban design concerns were raised in this regard.</p>

CLAUSE 58.07 - INTERNAL AMENITY

TITLE & OBJECTIVE	Assessment																					
<p>CLAUSE 58.07-1</p> <p>Functional layout objective</p> <p>To ensure dwellings provide functional areas that meet the needs of residents.</p> <p>Standard D26</p> <p>Bedrooms should:</p> <ul style="list-style-type: none"> • Meet the minimum internal room dimensions and area specified in Table D11. • Provide an area in addition to the minimum internal room dimensions and area to accommodate a wardrobe. <p>Living areas (excluding dining and kitchen areas) should meet the minimum internal room dimensions specified in Table D12.</p> <p>Table D11 Bedroom dimensions</p> <table border="1" data-bbox="300 943 775 1010"> <thead> <tr> <th>Bedroom type</th> <th>Minimum width</th> <th>Minimum depth</th> <th>Minimum area</th> </tr> </thead> <tbody> <tr> <td>Main bedroom</td> <td>3 metres</td> <td>3.4 metres</td> <td>10.2 sqm</td> </tr> <tr> <td>All other bedrooms</td> <td>3 metres</td> <td>3 metres</td> <td>9 sqm</td> </tr> </tbody> </table> <p>Table D12 Living area dimensions</p> <table border="1" data-bbox="300 1043 775 1111"> <thead> <tr> <th>Dwelling type</th> <th>Minimum width</th> <th>Minimum area</th> </tr> </thead> <tbody> <tr> <td>Studio and 1 bedroom dwelling</td> <td>3.3 metres</td> <td>10 sqm</td> </tr> <tr> <td>2 or more bedroom dwelling</td> <td>3.6 metres</td> <td>12 sqm</td> </tr> </tbody> </table>	Bedroom type	Minimum width	Minimum depth	Minimum area	Main bedroom	3 metres	3.4 metres	10.2 sqm	All other bedrooms	3 metres	3 metres	9 sqm	Dwelling type	Minimum width	Minimum area	Studio and 1 bedroom dwelling	3.3 metres	10 sqm	2 or more bedroom dwelling	3.6 metres	12 sqm	<p>All dwellings would meet the requirements of Table D11 and D12 in terms of bedroom and living area sizes. No changes are needed.</p>
Bedroom type	Minimum width	Minimum depth	Minimum area																			
Main bedroom	3 metres	3.4 metres	10.2 sqm																			
All other bedrooms	3 metres	3 metres	9 sqm																			
Dwelling type	Minimum width	Minimum area																				
Studio and 1 bedroom dwelling	3.3 metres	10 sqm																				
2 or more bedroom dwelling	3.6 metres	12 sqm																				
<p>CLAUSE 58.07-2</p> <p>Room depth objective</p> <p>To allow adequate daylight into single aspect habitable rooms.</p> <p>Standard D27</p> <ul style="list-style-type: none"> • Single aspect habitable rooms should not exceed a room depth of 2.5 times the ceiling height. • The depth of a single aspect, open plan, habitable room may be increased to 9 metres if all the following requirements are met: <ul style="list-style-type: none"> - The room combines the living area, dining area and kitchen. - The kitchen is located furthest from the window. - The ceiling height is at least 2.7 metres measured from finished floor level to finished ceiling level. This excludes where services are provided above the kitchen. • The room depth should be measured from the external surface of the habitable room window to the rear wall of the room. 	<p>The proposal would meet the standard as follows:</p> <ul style="list-style-type: none"> - Single aspect habitable rooms would not exceed a room depth of 2.5 times the ceiling height. - Open plan living rooms would achieve a minimum 2.7m height ceiling. - All living areas would be less than 9.0m to the back of the kitchen. - All bedroom ceiling height would be a minimum of 2.4m (2.4x2.5 = 6.0 maximum room depth). - Bedrooms depths would be less than 6.0m (including robe). 																					

<p>CLAUSE 58.07-3</p> <p>Window objective</p> <p>To allow adequate daylight into new habitable room windows.</p> <p>Standard D28</p> <ul style="list-style-type: none"> • Habitable rooms should have a window in an external wall of the building. • A window may provide daylight to a bedroom from a smaller secondary area within the bedroom where the window is clear to the sky. • The secondary area should be: <ul style="list-style-type: none"> – A minimum width of 1.2 metres. <p>A maximum depth of 1.5 times the width, measured from the external surface of the window.</p>	<p>All habitable rooms would have direct access to a window on the external wall of the building, complying with this standard.</p>
<p>CLAUSE 58.07-4</p> <p>Natural ventilation objectives</p> <ul style="list-style-type: none"> • To encourage natural ventilation of dwellings. • To allow occupants to effectively manage natural ventilation of dwellings. <p>Standard D29</p> <ul style="list-style-type: none"> • The design and layout of dwellings should maximise openable windows, doors or other ventilation devices in external walls of the building, where appropriate. • At least 40 per cent of dwellings should provide effective cross ventilation that has: <ul style="list-style-type: none"> – A maximum breeze path through the dwelling of 18 metres. – A minimum breeze path through the dwelling of 5 metres. – Ventilation openings with approximately the same area. • The breeze path is measured between the ventilation openings on different orientations of the dwelling. 	<p>At least 40% of dwellings would achieve effective cross ventilation with a maximum breeze path of 18m and a minimum path of 5m.</p>