



**NOTES**

1. Clean & reset bluestone pitchers on concrete base and 3% cement treated crushed rock (CTCR) sub-base.
2. Concrete strength: 25 MPa at 28 days.
3. Bluestone joints to be filled with a grout mix of: 16% cement, 16% stonedust, 67% blended washed sand and 1% lime with Bayer synthetic colour oxide added at a rate of 40 kg/m mixed through the grout or mortar (charcoal coloured grout).
4. Typical bluestone pitcher size of 150mm x 200mm is an average size only.
5. All grouted joints to be a min 10mm to max 30mm wide to full depth of pitcher.
6. All dimensions are in millimetres unless noted otherwise.

A APPROVED FOR USE		DEC 2020
No	Revision	Date

**Disclaimer:**  
The authors and sponsoring organisations shall have no liability or responsibility to the user or any other person or entity with respect to any liability, loss or damage caused or alleged to be caused, directly or indirectly, by the adoption and use of these Standard Drawings including, but not limited to, any interruption of service, loss of business or anticipatory profits, or consequential damages resulting from the use of these Standard Drawings. Persons must not rely on these Standard Drawings as the equivalent of, or a substitute for, project-specific design and assessment by an appropriately qualified professional.



DRAWING NOT TO SCALE	
Approved	Project Services
Date	Dec. 2020

Drawing Title	BLUESTONE PITCHER LANEWAY RIGHT OF WAY WITH CHANNEL	
Original Size	A3	Drawing No: CPP1601
Rev:	A	